



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 07, 2022

Inspection Result: PARTIAL PASS

Permit Number: B-21-0727

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: PHASE IIIA: SHELL FOR CLASSRMS; FINISH 1ST FL(5 CLASSRMS & ADMIN AREA)CCSBLDG

On this day we have inspected your construction for **Underfloor Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved roof sheathing.

Corrections:

- 1 1 ; complete all rebar as per City Approved plans & install of holdowns with min. embed depth as per engineers correction approval letter as at grid line - (1-2,C.5-E) (A,2-5) (5,A-E) exterior walls only.
- 2 ;approved with special inspection approval.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org