



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 14, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** B-20-0306

**Property Address:** 815 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** LOBBY ADDITION TO NORTH OF EXISTING GYM ~ CCS

BLDG/MECH/PLUMB

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; approved roof insulation only.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684