



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 14, 2022

Inspection Result: PASSED

Permit Number: B-20-0306

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: LOBBY ADDITION TO NORTH OF EXISTING GYM ~ CCS

BLDG/MECH/PLUMB

On this day we have inspected your construction for **Shear Wall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; complete shear wall nailing as per City approved plans and re nail overdriven nails at grid line - (a,2-5) (5,a-b2)

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684