



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application #B-21-0727

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: Janelle Montgomery, (253)770-3328, JMontgomery@PuyallupWA.gov)

♦ RESUBMITTAL APPLICATION NOTED CONNECT GAS TO CLASSROOM FROM LOBBY NO GAS SEMATIC PLANS PROVIDED. CONFIRM GAS PIPING SIZE OF GAS LINE, CONT. FROM 1" FROM M-2. WHERE IS POINT OF CONNECTION TO HOT WATER? ONLY SHOWS A GAS LINE.

To resubmit, you must address all comments and complete the [resubmittal form](#). When you are ready to resubmit, you can do so using the customer portal, by uploading a "new version" of the submittal requirement. In addition, you will need to **pay your resubmittal fee at the time of resubmittal**. Your resubmittal **will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov