



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # B-20-0306

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: Janelle Montgomery, (253)770-3328, JMontgomery@PuyallupWA.gov)

- ◆ Provide manufacturer's specification for hot water generator and details how it will meet seismic attachment requirements.
- ◆ PROVIDE LOCATION OF PROPOSED WATER GENERATOR

To resubmit, you must address all comments and complete the [resubmittal form](#). When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement. In addition, you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.** Please note, partial resubmittals will be deemed incomplete and returned.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov