



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 02, 2022

Inspection Result: NOT READY

Permit Number: B-21-0727

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: PHASE IIIA: SHELL FOR CLASSRMS; FINISH 1ST FL(5 CLASSRMS & ADMIN AREA)CCSBLDG

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. Rooms 112' 113 will be caped in the wall for future use permits required
Room 111 provide permits for eye washing station that is not on current city approved plans

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684