



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # B-21-0727

August 10, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: Janelle Montgomery, (253)770-3328, JMontgomery@PuyallupWA.gov)

- ◆ M1 - PROVIDE ENG SEAL FROM BRIAN MEDDLBROOK FOR THE UPDATED CHANGES TO HIS SEALED PLANS.
- ◆ REPEAT COMMENT: PROVIDE ENGINEERED SEAL PLANS.(ALL SHEETS)
- ◆ M5- Letter notes to see M5 in B-20-0306 did not have continuation. All information should be included in this revision but unable to verify as I could not locate.
- ◆ A2.1 - Provide updated plumbing plans (Revise P1.01 & P2.1) reflecting the plumbing reductions and where plumbing lines will be capped to be extended in the future.
- ◆ Truss Calc - Provide Engineer seal on calculations.
- ◆ Email: Provide Redbuilt analysis on the roof plan to document current framing is adequate. Include the plans enclosed in email within plans to support location etc. of new location of equipment.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov