



Jeff Brown Architecture

July 29, 2022

Janelle Montgomery, Senior Plans Examiner

City of Puyallup
333 South Meridian
Puyallup, WA 98372

RE: Revision Letter to revise **B-20-0609 (Lobby Addition)**

Thank you for providing comments on the B-20-0306 Lobby Addition for Cascade Christian School. In addition to comment responses, we have provided a design modified document for field **modifications** to accommodate future improvements.

Modifications

- A2.5 Roof plan – remove and relocate future DOAS system curb. This will be reflected on the B-21-0727 permit revision submittal
- M-2 Main floor HVAC Plan – Gas piping connection to the hot water heater

Comment

Provide manufacturer's specification for hot water generator and details how it will meet seismic attachment requirements

Response: See doc "CCS Lobby-Rev05-Supp_Gas HW.pdf" and "CCS Lobby-Rev05-Supp_HW Seismic detail.pdf"

Comment

Provide the location of proposed water generator

Response: See doc "CCS Lobby-Rev05-Drawing_Arch.pdf" page 1/5 (or A2.1). Janitor's closet (Rm # 116) plumbing fixture layout is updated. Also, see doc "CCS Lobby-Rev05-drawing_Plumb.pdf"

Thank you,

Songyi Cho

Jeff Brown Architecture
12181 C St S | Tacoma, WA 98444
songyi.cho@hotmail.com | 509.432.4651