



Jeff Brown Architecture

August 15, 2022

Janelle Montgomery, Senior Plans Examiner

City of Puyallup
333 South Meridian
Puyallup, WA 98372

RE: Revision Letter to revise **B-21-0727 (Classroom Addition)**

Thank you for providing comments on the B-21-0727 Classroom Addition for Cascade Christian School. Our response is below in Red.

Comments

M1 PROVIDE ENG SEAL FROM BRIAN MEDDLBROOK FOR THE UPDATED CHANGES TO HIS SEALED PLANS.

REPEAT COMMENT: PROVIDE ENGINEERED SEAL PLANS.(ALL SHEETS)

Sealed Mechanical drawings are provided

M5 Letter notes to see M5 in B-20-0306 did not have a continuation. All information should be included in this revision but unable to verify as I could not locate.

The "reference page (M2 from B-20-0306)" is attached to B-21-0727 Mechanical drawings.

A2.1 Provide updated plumbing plans (Revise P1.01 & P2.1) reflecting the plumbing reductions and where plumbing lines will be capped to be extended in the future.

Revised & Sealed plumbing drawings, P0.01 & P2.01 are provided

Truss Calc Provide Engineer seal on calculations.

Email: Provide Redbuilt analysis on the roof plan to document current framing is adequate. Include the plans enclosed in email within plans to support location etc. of new location of equipment.

Chris Fynboe, engineer in record reviewed and provide a stamp on calculation & analysis (Doc_TrussSealed)

Thank you,

Songyi Cho

Jeff Brown Architecture
12181 C St S | Tacoma, WA 98444
songyi.cho@hotmail.com | 509.432.4651