



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

August 29, 2022

CES NW Inc.

29th St. NE, suite D

Puyallup, WA 98372

submittals@cesnwinc.com

RE: Alternative Methods Request - PRAMR20221174 – 1200 7th Ave Town Homes

To CES NW Inc.:

The City reviewed the Alternative Methods Request requesting a standards deviation for the use of 8-in pipe for the 7th Ave SE storm crossing and curb inlet in lieu of a City Standard catch basin. Your request is **Approved** for the use of the curb inlet and **Denied** for the 8-in storm crossing. As discussed with CES NW, Inc., the project will relocate the existing gas main and existing watermain to allow a 12-in ductile iron storm crossing. The civil plans will be revised to reflect these.

If you have any questions regarding this decision, or would like to further discuss your request, please contact me at (253) 841-5559 or via email at MHigginson@PuyallupWA.gov

Sincerely,

Mark Higginson

Senior Civil Engineer