



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 08, 2022

**Inspection Result:** PASSED

**Permit Number:** B-21-0727

**Property Address:** 815 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

**To construct:** PHASE IIIA: SHELL FOR CLASSRMS; FINISH 1ST FL (5 CLASSRMS & ADMIN AREA) CCS BLDG - REVISION TO CONNECT WH FROM LOBBY TO CLASSROOM

On this day we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ;gas pipe test approved at 17 psi,

**Corrections:**

1 1 ; provide city approved gas piping plans at time on inspection,.

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684