



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 04, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-21-0727

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: PHASE IIIA: SHELL FOR CLASSRMS; FINISH 1ST FL (5 CLASSRMS & ADMIN AREA) CCS BLDG - REVISION TO CONNECT WH FROM LOBBY TO CLASSROOM

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. walls only no lids

Corrections:

- 1 1. room 113 provide nail plates at DWV
2. Room 110 add anchor bolts where missing
3. Room 112 provide nail plates at DWV
4. Room 112 complete shear nailing at top of wall [east wall]
5. room 109 provide nail plate at DWV
6. Provide anchor bolts at end of hallway on each side of door
7. room 108 provide positive connection at sill plate
8. complete SDS screws in rim at hallway
9. OK TO INSULATE
- 2 1. provide positive connection at stair stringers
2. complete poly seal at all penetration's as discussed with contractor

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large initial 'S' and 'K'.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684