



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 16, 2022                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCA20220580

**Property Address:** 815 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** J & C BERGMAN CONTRACTING P.O. BOX 732091 PUYALLUP, WA  
98373 Jake Bergman PO BOX 732091 PUYALLUP, WA 98373 (253) 961-  
0602

**To construct:** Minor interior TI & Adding 1771 SF to the existing office building

On this day we have inspected your construction for **Storm Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Need a clean out on the 6". Okay to install a 6" tee straight up. Top of tee will be the clean out.

**Corrections:**

Sincerely,

Jason Little  
Engineering Tech IV



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

JLittle@PuyallupWA.gov

(253) 435-3636