



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 20, 2022

Inspection Result: NOT READY

Permit Number: B-21-0727

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: PHASE IIIA: SHELL FOR CLASSRMS; FINISH 1ST FL (5 CLASSRMS & ADMIN AREA) CCS BLDG - REVISION TO CONNECT WH FROM LOBBY TO CLASSROOM

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: -Connect downspouts on north side of BLDG.
-Landscape/stabilize exposed soils of the west side of BLDG. Slope away from BLDG.
-Cut down storm drain cleanouts, install threaded cap & adaptors, and Carson Box (or equal).

Corrections:

Sincerely,

Michael Rosenau
Engineering Tech IV
MRosenau@PuyallupWA.gov
(253) 841-5411