



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 20, 2022

Inspection Result: **IN PROGRESS**

Permit Number: B-20-0306

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: LOBBY ADDITION TO NORTH OF EXISTING GYM ~ CCS

On this day we have inspected your construction for **Planning Review** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: REVIEW OF PLANS - No Comments

Corrections:

Sincerely,

Chris Beale

Senior Planner

CBeale@PuyallupWA.gov

(253) 841-5418