



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 20, 2022 **Inspection Result:** **FAILED**

Permit Number: B-21-0727

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: PHASE IIIA: SHELL FOR CLASSRMS; FINISH 1ST FL (5 CLASSRMS & ADMIN AREA) CCS BLDG - REVISION TO CONNECT WH FROM LOBBY TO CLASSROOM

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. ; provide balance report as discussed with contractor.
- 2 ; paint gas pipe on roof.
- 3 ; protect insulation on refrigeration line set from u.v. rays.
- 4 ; seal penetration in exterior of building at refrigeration line set.
- 5 ; complete install of ladder for roof to access.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684