



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 06, 2023

Inspection Result: **FAILED**

Permit Number: B-20-0306

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152

To construct: LOBBY ADDITION TO NORTH OF EXISTING GYM ~ CCS

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 -Cut down C.O.'s on east end of building and all along the south side of the building, install threaded adaptors, threaded caps, and Carson boxes.

Sincerely,

Michael Rosenau
Engineering Tech IV
MRosenau@PuyallupWA.gov
(253) 841-5411