

STORM PUMP AND FORCE MAIN CALCULATIONS

Freeman Logistics

22nd Ave NW and 82nd Ave E
Puyallup, WA

Prepared for:

Vector Development Company
11411 NE 124th Street, Suite 190
Kirkland, WA 98034



October 14th, 2022
REVISED: November 2023

Our Job No. 21585

TABLE OF CONTENTS

1.0 INTRODUCTION/GENERAL INFORMATION

FIGURE 1 VICINITY MAP

APPENDICES

APPENDIX A Pump Designs

APPENDIX B Force Main Sizing

APPENDIX C Buoyancy Calculations

APPENDIX D Pump Details

APPENDIX E Operations and Maintenance Manual

1.0 INTRODUCTION/GENERAL INFORMATION

The following pages of this report delineate the criteria followed and the methodology used for sizing the storm pump and force main servicing the Freeman Logistics project.

The project includes 2 warehouse buildings with associated parking and frontage improvements totaling 25.50 acres of total disturbed area. Onsite, two separate detention vaults are proposed. The frontage improvement will be collected and detained separately with a detention tank. These detention facilities will detain and release stormwater in accordance with the Flow Control Standard per the Department of Ecology drainage manual (2019 Department of Ecology manual). The 100-year peak storm release rate of the vaults is 2.242 ft³/sec. Released stormwater will then be treated for water quality using a DOE-approved proprietary structure. Following treatment, all flows, both onsite and offsite, will be conveyed to a manhole pump station. The pump station will convey flows northwest via a new 6-inch force main and then release further downstream, within an existing structure within the private road 78th Ave E. The new force main will be approximately 2,515 feet in length.


Emergency standby power is proposed using a generator (natural gas or approved alternative). Additional storage volume is not required downstream of the detention vault.

This report also includes buoyancy calculations for the pump manhole due to the shallow seasonal high groundwater elevation on the site.

Figure 1

Vicinity Map





REFERENCE: MapQuest (2022)

Scale:

Horizontal: N.T.S.

Vertical: N/A



**Barghausen
Consulting Engineers, Inc.**

18215 72nd Avenue South

Kent, WA 98032

425.251.6222

barghausen.com

For:

**Freeman Road Logistics
Fife, Washington**

Title:

VICINITY MAP


Job Number

21585

DATE: 09/01/22

Appendix A

Pump Design



STORM PUMP DESIGN

Pump Criteria:

- Design a submersible duplex pump with variable speed which can meet or exceed the 100-year peak release rate of the detention system.

100-year peak release rate of combined facilities = 2.24 cfs = 1,006 gpm

- **Suggested pump size = dual 600 gpm at ± 75 -feet TDH**

Pump Cycles

- To meet the desired discharge characteristics for matching the flow control standard, the pump controls include a VFD (Variable Frequency Drive) and level sensor which allow a wide range of pump speed to match the outflow rate from the control structure on the vault. The pumps can be controlled down to a flow rate of approximately 90 gpm. Assuming the pump starts at the lowest speed, the cycle time would be:


Wet well storage = Pump On - Pump Off x 118.96 gallons per linear feet of MH = 13.94 – 11.44 x 118.96 = 446 gallons

Cycle time = 446 gal / 45 gpm = 9.91 minutes

Cycles per hour = 6.05

Appendix B

Force Main Sizing



STORM FORCE MAIN DESIGN

Pump System

Force main design for proposed force main:

- Design flow in the force main = 600 gpm = 1.34 cfs
- Use 6-inch force main
 - Velocity = $1.34 \text{ cfs} / 0.196 \text{ sf} = 6.84 \text{ fps}$
 - $6.84 \text{ fps} < 8 \text{ fps}$ OK

Static Head = Invert at downstream end of force main - Pump Off Elevation

Invert elevation at tie-in structure = 27.73

Pump off elevation = 10.50

Static Head = $27.73 - 10.50 = \pm 17.5 \text{ feet}$

Total Dynamic Head = based on pump configuration and force main (to be verified by pump manufacturer)

Force Main is HDPE (Sch. 40 Pipe)

New 6" Force Main Pipe Length = 2,515 feet

Friction loss in 6-inch main = $2,515 / 100 \times 2.19 = 55.1 \text{ feet}$

Fitting losses in equivalent length of 6" straight pipe (From Friction Loss chart)

Elbows and valves: 90 deg = 15.2
 45 deg = 8.1
 Ball & check valve = 4

Head loss = $(15.2 + (2)(8.1) + 4) / 100 \times 1 = 0.35 \text{ feet}$

Total Head = Static Head + Friction Loss = 17.5 + 55.1 feet + 0.35 feet = 72.95 feet

Pump System

Pump Station Control Panel Specification

Primary power shall be from the proposed recreational building. Contractor is to verify available power source and sizing prior to ordering the pump station. Each pump system shall have its own control panel.

The control panel for each sanitary pump station shall include:

- Control for a duplex pump system (controls to be hard wired)
- VFD control for each pump
- Enclosure for installation outside (installation to be near the pump station)
- Visual alarm – flashing light
- Display at control panel to monitor station performance
- 12-hour battery backup for control panel
- Manual and remote reset for alarms
- Alarms for:
 - Pump failure
 - Seal failure
 - High temperature
 - Low water
 - High water
 - Low battery
 - Power failure
- Duplex cycle counter
- Duplex elapsed run time meter
- Surge protection
- Dial up to 8 phone numbers during an alarm condition
- Minimum 1 year warranty

Table A.2 Friction Loss Data for PVC Pipe. Data courtesy IPEX Inc.

GPM	cu ft / sec	Velocity (ft/s)	Friction Head Loss (ft water / 100 ft)	Friction Pressure (psi / 100 ft)	Velocity (ft/s)	Friction Head Loss (ft water / 100 ft)	Friction Pressure (psi / 100 ft)	Velocity (ft/s)	Friction Head Loss (ft water / 100 ft)	Friction Pressure (psi / 100 ft)	Velocity (ft/s)	Friction Head Loss (ft water / 100 ft)	Friction Pressure (psi / 100 ft)
1	0.002	1/2"			3/4"			1"			1 1/4"		
2	0.004	1.13	1.16	0.50	1.26	1.03	0.44	1.93	1.69	0.73	1.10	0.43	0.19
5	0.011	2.26	4.19	1.81	3.16	5.60	2.42	2.70	3.14	1.36	1.55	0.81	0.35
7	0.016	5.64	22.88	9.90	4.43	10.44	4.52	3.86	6.08	2.63	2.21	1.57	0.68
10	0.022	7.89	42.66	18.47	6.32	20.21	8.75	4.63	8.53	3.69	2.65	2.20	0.95
12	0.027				7.59	28.33	12.26	5.79	12.89	5.58	3.31	3.32	1.44
15	0.033				9.48	42.82	18.54	7.72	21.96	9.51	4.42	5.65	2.45
20	0.045							9.65	33.20	14.37	5.52	8.55	3.70
25	0.056							11.58	46.54	20.15	6.63	11.98	5.19
30	0.067										7.73	15.94	6.90
35	0.078	4"									8.84	20.41	8.84
40	0.089										9.94	25.39	10.99
45	0.100	1.15	0.13	0.06							11.05	30.86	13.36
50	0.111	1.28	0.16	0.07	5"								
55	0.123	1.41	0.19	0.08	1.14	0.10	0.04						
60	0.134	1.53	0.23	0.10	1.22	0.11	0.05	6"					
65	0.145	1.66	0.26	0.11	1.30	0.13	0.06	1.12	0.08	0.03			
70	0.156	1.79	0.30	0.13	1.46	0.16	0.07	1.40	0.12	0.05			
75	0.167	1.92	0.34	0.15	1.62	0.19	0.08	1.69	0.17	0.07	8"		
80	0.178	2.05	0.39	0.17	2.03	0.29	0.13	1.97	0.22	0.10	1.30	0.08	0.03
90	0.201	2.30	0.48	0.21	2.44	0.41	0.18	2.25	0.29	0.12	1.62	0.11	0.05
100	0.223	2.56	0.59	0.25	2.84	0.55	0.24	2.81	0.43	0.19	1.94	0.16	0.07
125	0.279	3.20	0.89	0.38	3.25	0.70	0.30	3.37	0.61	0.26	2.27	0.21	0.09
150	0.334	3.84	1.24	0.54	4.06	1.06	0.46	4.49	1.03	0.45	2.59	0.27	0.12
175	0.390	4.47	1.65	0.72	4.87	1.49	0.64	5.06	1.29	0.56	2.92	0.34	0.15
200	0.446	5.11	2.12	0.92	5.69	1.98	0.86	5.62	1.56	0.68	3.24	0.41	0.18
250	0.557	6.39	3.20	1.39	6.50	2.54	1.10	6.74	2.19	0.95	3.89	0.57	0.25
300	0.668	7.67	4.49	1.94	7.31	3.15	1.36	7.87	2.92	1.26	4.54	0.76	0.33
350	0.780	8.95	5.97	2.58	8.12	3.83	1.66	8.99	3.73	1.62	5.18	0.98	0.42
400	0.891	10.23	7.64	3.31	9.75	5.37	2.33	10.11	4.64	2.01	5.83	1.22	0.53
450	1.003				11.37	7.15	3.09				6.48	1.48	0.64
500	1.114	18"						24"			8.10	2.24	0.97
600	1.337				20"						9.72	3.14	1.36
700	1.560				1.75	0.05	0.02						
800	1.782	1.30	0.03	0.01	2.33	0.08	0.04	2.01	0.05	0.02			
900	2.005	1.45	0.04	0.02	2.91	0.12	0.05	2.41	0.07	0.03			
1000	2.228	1.81	0.06	0.03	3.49	0.17	0.08	2.81	0.09	0.04			
1250	2.785	2.17	0.08	0.04	4.07	0.23	0.10	3.22	0.12	0.05			
1500	3.342	2.89	0.14	0.06	4.65	0.30	0.13	3.62	0.15	0.06			
2000	4.456	3.62	0.21	0.09	5.24	0.37	0.16	4.02	0.18	0.08			
2500	5.570	4.34	0.29	0.13	5.82	0.45	0.19	4.42	0.22	0.09			
3000	6.684	5.06	0.39	0.17	6.40	0.53	0.23	4.83	0.25	0.11			
3500	7.798	5.79	0.50	0.22	6.98	0.63	0.27	5.23	0.30	0.13			
4000	8.912	6.51	0.62	0.27	7.56	0.73	0.31	5.63	0.34	0.15			
4500	10.026	7.23	0.76	0.33	8.14	0.83	0.36	6.03	0.39	0.17			
5000	11.140	7.96	0.91	0.39	8.73	0.95	0.41	6.43	0.43	0.19			
5500	12.254	8.68	1.06	0.46	9.31	1.07	0.46	6.84	0.49	0.21			
6000	13.368	9.40	1.23	0.53	9.89	1.19	0.52	7.24	0.54	0.23			
6500	14.482	10.13	1.42	0.61	10.47	1.33	0.57	7.64	0.60	0.26			
7000	15.596							8.04	0.66	0.28			
7500	16.710												
8000	17.824												
8500	18.938												
9000	20.052												
9500	21.166												
10000	22.280												




Figure A.1 Graphical depiction of friction loss through PVC pipe. Data courtesy IPEX Inc.


Table A.3 Friction Loss Through Fittings in Equivalent Footage of Pipe. Data Courtesy IPEX Inc.

Size (in.)	FITTINGS			
	Tee Run	Tee Branch	90° Elbow	45° Elbow
1/2	1.0	3.8	1.5	0.8
3/4	1.4	4.9	2.0	1.1
1	1.7	6.0	2.5	1.4
1 1/4	2.3	7.3	3.8	1.8
1 1/2	2.7	8.4	4.0	2.1
2	4.0	12.0	5.7	2.6
2 1/2	4.9	14.7	6.9	3.1
3	6.1	16.4	7.9	4.0
4	7.9	22.0	11.4	5.1
6	12.3	32.7	16.7	8.0
8	14.0	49.0	21.0	10.6
10	17.5	57.0	26.0	13.5
12	20.0	67.0	32.0	15.5
14	25.0	78.0	37.0	18.0
16	27.0	88.0	43.0	20.0
18	32.0	107.0	53.0	23.0
20	35.0	118.0	58.0	25.0
24	42.0	137.0	67.0	30.0

Appendix C

Buoyancy

Calculations



FREEMAN STORM BUOYANCY CALCULATIONS

- **SD Pump Manhole, Type 2 - 54 inches**

Rim: 32.64

Inside Bottom = 8.10

Outside Bottom = 7.43

- **Weight of Manhole**

Top Slab = ~2,600 lbs

Barrell = 1,100 lb/lf x (32.64 - 0.67 - 12.43) = 21,494 lbs

Bottom 5' base = 7,600 lbs

Total (manhole) = 31,694 lbs

$P_{\text{Manhole}} = 31.7 \text{ Kip}\downarrow$

- **Water Weight**

Max groundwater height (~5' bge) = 27.64 feet

Manhole displacement = $(27.64 - 7.43) \times \pi r^2 = 20.21 \pi (2.625)^2 = 437.3 \text{ CF}$

Water unit weight = 62.4 lb/ft³

$P_{\text{Water}} = 437.3 \times 62.4 = 27,285 \text{ lb} = 27.3 \text{ Kip}\uparrow$

- **Buoyancy**

$\Sigma F = P_{\text{Manhole}} - P_{\text{Buoyancy}} = 31.7\text{K}\downarrow - 27.3\text{K}\uparrow = 4.4 \text{ K}\downarrow$

$$FS = \frac{31.7}{27.3} = 1.16$$