

April 5, 2024

Robert W Landa  
Studio Meng Strazzara  
2001 Western Ave, Suite #200, Seattle, WA 98121

RE: Site Review – Puyallup High School portable addition

Tacoma-Pierce County Health Department has completed a site review for Puyallup School District for the following site:

**Puyallup High School – 105 7th ST SW, Puyallup, WA 98371 – Parcels 5870000190 and 5870000231 where new portables will be placed.**

The following items were reviewed:

- Water supply
- Sewage disposal
- Site size
- Noise levels\*
- Environmental contaminants
- Health and safety

As a result of this review, this site is hereby approved for the addition of three double dry portables.

\*Noise levels exceeded allowable site allowance levels. Per sound study, additional interior sound level measurements will be conducted after the portables are installed to determine if additional noise reduction mitigation is required. A full weekday of data must be collected. This must be provided to show noise level requirements are met.

This site review is valid for two years. If plan review applications have not been submitted for the project within that period, a new site review application will be required.

If you have any questions regarding this information, you may contact me at (253) 649-1712.

Sincerely,



Lori Karnes, RS  
Environmental Health Specialist Supervisor  
Food and Community Safety Program  
Tacoma-Pierce County Health Department  
(253) 649-1712  
[lkarnes@tpchd.org](mailto:lkarnes@tpchd.org)