

City of Puyallup **Planning Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

August 08, 2024

Cheryl Ebsworth 18215 72nd Avenue South Kent, WA 98032

| FINAL DEVELOPMENT REVIEW TEAM (DRT) LETTER |   |  |  |  |
|--|---|--|--|--|
| PERMIT #                                   | PLVAR20230125   |  |  |  |
| PROJECT NAME                               | Freeman Road Logistics  |  |  |  |
| PERMIT TYPE                                | Variance  |  |  |  |
| PROJECT DESCRIPTION                        | Reduction of southern landscaping buffer from the 35' wide type Ia buffer required by PMC 20.35.020 (8) to a 12' wide Id buffer which would include a berm, retaining wall and 6' wood fence, similar to the reduction allowed by PMC 20.26.500 (1).  |  |  |  |
| SITE ADDRESS                               | 5117 FREEMAN RD E, PUYALLUP, WA 98371;  |  |  |  |
| PARCEL #                                   | 0420205003;   |  |  |  |
| ASSOCIATED LAND USE<br>PERMIT(S)           | P-2I-0I36<br>P-2I-00II  |  |  |  |
| APPLICATION DATE                           | January 11, 2024  |  |  |  |
| APPLICATION<br>COMPLETE DATE               | January 11, 2024  |  |  |  |
| PROJECT STATUS                             | <b>Final Development Review Team (DRT) letter.</b> The latest revised copy of submitted materials has fulfilled the city's requirements related to the land use permit in accordance with the following conditions and notes. The project is now proceeding into the scheduling of a public hearing on the project. |  |  |  |
| APPROVAL EXPIRATION                        | See PMC 20.85.025 and .030.   |  |  |  |
| CONDITIONS                                 | <u>See notes and conditions below</u> . The project shall conform to all conditions outlined herein and shall comply with all applicable provisions of the Municipal Code and any SEPA conditions (if SEPA environmental review was performed).   |  |  |  |

## HOW TO USE THIS LETTER

The "**Conditions**" are items that will govern the final permit submittal(s) for the project. Please be aware that these conditions will become conditions of the final permits and/or recommendations to the Hearing Examiner, if applicable.

If you have questions regarding the action items or conditions outlined in this letter, please contact the appropriate staff member directly using the phone number and/or email provided.

## CONDITIONS

The following are conditions of approval. All future civil and/or building permit submittals shall comply with the following conditions, if any. Each condition has been added by a specific City of Puyallup Department, please contact the specific reviewer associated with that condition for any specific questions regarding that condition:

| Department  | Reviewer           | Phone      | Email                      |
|-------------|--------------------|------------|----------------------------|
| Planning    | Chris Beale        | 2538415418 | CBeale@PuyallupWA.gov      |
| Engineering | Jamie Carter       | 2534353616 | JCarter@puyallupwa.gov     |
| Traffic     | Bryan Roberts      | 2538415542 | broberts@PuyallupWA.gov    |
| Building    | Janelle Montgomery | 2537703328 | JMontgomery@PuyallupWA.gov |
| Fire        | David Drake        | 2538644171 | DDrake@PuyallupWA.gov      |

| Condition<br>Category | Condition   | Department              | Condition<br>Status                    |
|-----------------------|---|-------------------------|--|
| Public Noticing       | Public notice sign must be posted on site in a publically visible location.   | Planning<br>Division    | Resolved                               |
| Public Noticing       | Signed Affidavit must be provided.  | Planning<br>Division    | Resolved                               |
|                       | Please note: Walls that exceed a total of 4 feet (toe to top) require building permits.   | Engineering<br>Division | Click or tap<br>here to<br>enter text. |
|                       | The following conditions shall be recommended to the Hearing Examiner:  | Planning<br>Division    | Open                                   |
|                       | LANDSCAPE CONDITION: Conifer trees ('Excelsa'<br>Western Redcedar) shall be planted at 15' on center<br>in the south buffer area. Preliminary plan set shows<br>trees at 25' on center.   |                         |  |
|                       | LANDSCAPE CONDITION: Conifer trees shall be at least eight feet tall at the time of planting.   |                         |  |
|                       | LANDSCAPE CONDITION: Evergreen understory<br>shrubs (at least three-gallon container size) spaced<br>no more than five feet on center shall be planted<br>throughout the southern landscape buffer. Ground<br>cover species shall be planted at two feet on center<br>throughout the southern landscape buffer. |                         |  |
|                       | LANDSCAPE CONDITION: At least 50 percent of<br>all plant species shall be PNW native per section 7.3<br>of the Puyallup Vegetation Management Standards<br>(VMS) manual. Daffodil bulbs shall be planted per the<br>standards of section 7.4 of the VMS.  |                         |  |

| Condition<br>Category | Condition  | Department | Condition<br>Status |
|-----------------------|--|------------|---------------------|
|                       | LANDSCAPE CONDITION: The southern<br>landscape buffer shall be irrigated to ensure plant<br>survival. The applicant shall post an assignment of<br>funds equal to 125% material and installation to<br>ensure plant establishment, survival and replacement<br>of dead plants over a three year monitoring period. |            |                     |
|                       | LANDSCAPING CONDITION: All standards in the VMS manual shall be observed, including top soil installation (section 8.2) and mulching (section 8.3).  |            |                     |

Sincerely,

Chris Beale Senior Planner (253) 841-5418 CBeale@PuyallupWA.gov