

43RD AVENUE MULTI-FAMILY
SITE LIGHTING

A PORTION OF THE NW 1/4 OF THE NE 1/4, SECTION 9, TOWNSHIP 19 NORTH, RANGE 4 EAST, W.M.
CITY OF PUYALLUP, PIERCE COUNTY, WASHINGTON



Statistics					
Description	Symbol	Avg	Max	Min	Avg/Min
SITE	+	1.0 fc	2.1 fc	0.2 fc	5.0:1
OFF-SITE	+	0.1 fc	0.8 fc	0.0 fc	N/A

Schedule						
Symbol	Label	Image	QTY	Description	Lamp Output	Input Power
☐	A1		5	Lithonia Lighting D-Series Size 0 Area Luminaire P1 Performance Package 3000K CCT 70 CRI Type 3 Medium Houseside Shield, 15-Foot Anchor Base Pole	3985	0.9
☐	A2		1	Lithonia Lighting D-Series Size 0 Area Luminaire P1 Performance Package 3000K CCT 70 CRI Type 4 Medium, 15-Foot Anchor Base Pole	4666	0.9
⊗	W1		9	Lithonia Lighting D-Series Size 1 Wallpack 4000 3000K 70CRI Type 3 Medium, Mount At +18' (Verify Mounting Height With Architect)	2972	0.9

SITE DATA
ADDRESS: 701 43RD AVE SW
TPN: 4320000160

SITE LIGHTING

TITLE CLIENT



Know what's below.
Call 811 before you dig.
DigsafeWA.com

DATE SEALED

PROJECT MANAGER
G. JELLISON

DESIGN CTU

DRAWN AD

CHECKED CTU

SEC 9 T 19 N R 4 E

DATE 01/16/25

SHEET 1 OF 1

FILE NO 35043-01

© APEX ENGINEERING LLC 2025



2601 South 35th St., Suite 200
Tacoma, Washington 98409-7479
(253) 473-4494 FAX: (253) 473-0599

DJL INVESTMENTS LLC

P.O. BOX 26446

FEDERAL WAY, WA 98001

ATTN: DAVID LITOWITZ (253) 988-8815

PRELIMINARY



HULTZ BHU
engineers inc

1111 Fawcett Ave, Suite 100
Phone: (253) 383-3257
general@hultzbhu.com

Tacoma, WA 98402
Fax: (253) 383-3283
Job Number: 25-066