

December 17, 2021

Record ID: SR0268455

ATTN NABILA COMSTOCK
CITY OF PUYALLUP
333 S MERIDIAN
PUYALLUP WA 98371
NCOMSTOCK@PUYALLUPWA.GOV

RE: SEPA Review, Freeman Logistics P-21-0136

Dear Nabila Comstock:


The Tacoma-Pierce County Health Department's Environmental Health Program received the above mentioned checklist on November 22, 2021 and has the following comment(s):

All wells that will not be included in the public water system for this project must be properly decommissioned per WAC 173-160 prior to final application approval. The Tacoma-Pierce County Health Department must be contacted 48 hours prior to any decommissioning activity at the site. Decommissioning should be done by a licensed well driller. Contact Jeremy Bush at (253) 649-1805, for applications to decommission.

When an existing on-site sewage disposal system is abandoned, the Tacoma-Pierce County Health Department requires all tanks pumped by a certified septage hauler, all tanks filled with soil, and a Decommissioning Application be completed, pursuant to Environmental Health Code, Chapter 2, On-Site Sewage. Please contact George Waun at (253) 798-6485 for further information.

Thank you for the opportunity to respond.

Sincerely,



Erica Welborn
Environmental Health Specialist II
Environmental Health Division