

# SEPA Comment Letter

January 06, 2022

Record ID: SR0268662

ATTN CHRIS BEALE  
CITY OF PUYALLUP  
333 S MERICIAN  
PUYALLUP WA 98371  
NCOMSTOCK@PUYALLUPWA.GOV

**RE: SEPA Review, Larson River Road Storage #P-21-0087**

Dear Chris Beale:

The Tacoma-Pierce County Health Department's Environmental Health Program received the above mentioned checklist on December 07, 2021 and has the following comment(s):

*The removal and installation of all Underground Storage Tanks (UST) in Pierce County must meet state and Tacoma-Pierce County Health Department (Health Department) requirements. Prior to the removal of UST's a permit must be obtained from the Health Department. If underground storage tank and/or contamination are found, ensure to follow regulations for clean-up and removal of tank. Please contact Rob Olson at (253) 649-1856 for further information.*

Thank you for the opportunity to respond.

Sincerely,



Erica Welborn  
Environmental Health Specialist II  
Environmental Health Division