

No scale located on plans - please submit with scale shown [site plan sheet 1]

Provide 12' sidewalk - required to provide required 8' walk with 4' X 10' street tree boxes. Depth of rear parking stalls can be reduced by 5' to shift site plan and ROW line to accommodate without impacting bldg footprints [site plan sheet 1]

Residential zone line. Relevant to the design review criteria [site plan sheet 1]

Parking lot islands required at 15' at widest point [site plan sheet 1]

Convert stalls to 8' X 15'; compact stalls [site plan sheet 1]

Mark-up Legend

| |
|---------------------|
| Building Review |
| Engineering Review |
| Fire Review |
| Planning Review |
| Public Works Review |
| Traffic Review |

- LANDSCAPE
- BUILDING-PROPOSED
- PARKING / DRIVE ASPHALT
- SIDEWALK-CONCRETE
- CROSSWALK
- CIRCULATION/BOH/TRASH

